

1448-114

2/28/2013

1/10



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY  
WASHINGTON, DC 20460

FEB 28 2013

OFFICE OF  
PREVENTION, PESTICIDES  
AND TOXIC SUBSTANCES

Glenda Akins  
Regulatory Affairs Manager  
Buckman Laboratories  
1256 N. McLean Blvd.  
Memphis, TN 38108

Subject: **W-60-1**  
EPA Registration No. 1448-114  
Application Date: January 23, 2013  
Receipt Date: January 29, 2013

Dear Ms. Akins:

This acknowledges receipt of your letter of January 25, 2013 submitted under the provision of PR Notice 98-10, and FIFRA section 3(c) 9.

**Proposed Notification:**

Registrant is updating product labels with different unit packing with container and disposal requirement language.

**General Comment:**

Based upon a review of the material submitted, your notification to add unit packaging and disposal language is acceptable. A copy of the label has been placed on file.

Should you have any questions or comments concerning this letter, you may contact me by telephone at (703) 308-6416 or by e-mail at [Campbell-Mcfarlane.Jacqueline@epa.gov](mailto:Campbell-Mcfarlane.Jacqueline@epa.gov) or Glen McLeod by telephone at (703) 347-0181 or by e-mail at [mcleod.glen@epa.gov](mailto:mcleod.glen@epa.gov). When submitting information or data in response to this letter, a copy of this letter should accompany the submission to facilitate processing.

Sincerely,

  
Jacqueline Campbell  
Product Manager (34)  
Regulatory Management Branch II  
Antimicrobials Division (7510P)

Please read instructions on reverse before completing form.

Form Approved. OMB No. 2070-0060

Print Form



United States  
Environmental Protection Agency  
Washington, DC 20460

<input type="checkbox"/>	Registration
<input type="checkbox"/>	Amendment
<input checked="" type="checkbox"/>	Other

OPP Identifier Number

Application for Pesticide - Section I

1. Company/Product Number 1448-114	2. EPA Product Manager J. Campbell - McFarlane	3. Proposed Classification <input checked="" type="checkbox"/> None <input type="checkbox"/> Restricted
4. Company/Product (Name) Buckman Laboratories, Inc./W-60-1	PM# 34	
5. Name and Address of Applicant (Include ZIP Code)  Buckman Laboratories, 1256 N. McLean Blvd. Memphis, TN 38108  <input type="checkbox"/> Check if this is a new address	6. Expedited Review. In accordance with FIFRA Section 3(c)(3) (b)(i), my product is similar or identical in composition and labeling to: EPA Reg. No. _____ Product Name _____	

Section - II

<input type="checkbox"/> Amendment - Explain below.	<input type="checkbox"/> Final printed labels in response to Agency letter dated _____
<input type="checkbox"/> Resubmission in response to Agency letter dated _____	<input type="checkbox"/> "Me Too" Application.
<input checked="" type="checkbox"/> Notification - Explain below.	<input type="checkbox"/> Other - Explain below.

Explanation: Use additional page(s) if necessary. (For section I and Section II.)

Notification of Unit Packaging

Section - III

1. Material This Product Will Be Packaged In:				2. Type of Container	
Child-Resistant Packaging <input type="checkbox"/> Yes* <input checked="" type="checkbox"/> No	Unit Packaging <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Water Soluble Packaging <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input checked="" type="checkbox"/> Metal <input type="checkbox"/> Plastic <input type="checkbox"/> Glass <input type="checkbox"/> Paper <input type="checkbox"/> Other (Specify) _____		
* Certification must be submitted		If "Yes" Unit Packaging wgt. 1 gallon	No. per container 4	If "Yes" Package wgt.	No. per container
3. Location of Net Contents Information <input checked="" type="checkbox"/> Label <input type="checkbox"/> Container		4. Size(s) Retail Container see attachment		5. Location of Label Directions <input checked="" type="checkbox"/> On Label <input type="checkbox"/> On Labeling accompanying product	
6. Manner in Which Label is Affixed to Product <input type="checkbox"/> Lithograph <input checked="" type="checkbox"/> Paper glued <input type="checkbox"/> Stenciled			<input type="checkbox"/> Other _____		

Section - IV

1. Contact Point (Complete items directly below for identification of individual to be contacted, if necessary, to process this application.)		
Name Glenda Akins	Title Regulatory Affairs Mgr	Telephone No. (Include Area Code) 901-272-6268
<b>Certification</b> I certify that the statements I have made on this form and all attachments thereto are true, accurate and complete. I acknowledge that any knowingly false or misleading statement may be punishable by fine or imprisonment or both under applicable law.		6. Date Application Received (Stamped)
2. Signature 	3. Title Regulatory Affairs Manager	
4. Typed Name Glenda Akins	5. Date Jan 23, 2013	

Please read instructions on reverse before completing form.

Form Approved. OMB No. 2070-0080

	United States <b>Environmental Protection Agency</b> Washington, DC 20460	<input type="checkbox"/> Registration <input type="checkbox"/> Amendment <input checked="" type="checkbox"/> Other	OPP Identifier Number
--	---	--	-----------------------

**Application for Pesticide - Section I**

<b>1. Company/Product Number</b> 1448-114	<b>2. EPA Product Manager</b> J. Campbell - McFarlane	<b>3. Proposed Classification</b> <input checked="" type="checkbox"/> None <input type="checkbox"/> Restricted
<b>4. Company/Product (Name)</b> Buckman Laboratories, Inc./W-60-1	<b>PM#</b> 34	
<b>5. Name and Address of Applicant (Include ZIP Code)</b> Buckman Laboratories, 1256 N. McLean Blvd. Memphis, TN 38108  <input type="checkbox"/> Check if this is a new address		<b>6. Expedited Review.</b> In accordance with FIFRA Section 3(c)(3) (b)(i), my product is similar or identical in composition and labeling to: EPA Reg. No. _____  Product Name _____

**Section - II**

<input type="checkbox"/> Amendment - Explain below.	<input type="checkbox"/> Final printed labels in response to Agency letter dated _____
<input type="checkbox"/> Resubmission in response to Agency letter dated _____	<input type="checkbox"/> "Me Too" Application.
<input checked="" type="checkbox"/> Notification - Explain below.	<input type="checkbox"/> Other - Explain below.

**Explanation:** Use additional page(s) if necessary. (For section I and Section II.)

Notification of Unit Packaging

**Section - III**

<b>1. Material This Product Will Be Packaged In:</b>				<b>2. Type of Container</b>	
<b>Child-Resistant Packaging</b> <input type="checkbox"/> Yes* <input checked="" type="checkbox"/> No	<b>Unit Packaging</b> <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No If "Yes" Unit Packaging wgt. 1 quart	<b>Water Soluble Packaging</b> <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If "Yes" Package wgt. 12			<input checked="" type="checkbox"/> Metal <input type="checkbox"/> Plastic <input type="checkbox"/> Glass <input type="checkbox"/> Paper <input type="checkbox"/> Other (Specify) _____
<b>3. Location of Net Contents Information</b> <input checked="" type="checkbox"/> Label <input type="checkbox"/> Container		<b>4. Size(s) Retail Container</b> see attachment		<b>5. Location of Label Directions</b> <input checked="" type="checkbox"/> On Label <input type="checkbox"/> On Labeling accompanying product	
<b>6. Manner in Which Label is Affixed to Product</b> <input type="checkbox"/> Lithograph <input checked="" type="checkbox"/> Paper glued <input type="checkbox"/> Stenciled				<input type="checkbox"/> Other _____	

**Section - IV**

<b>1. Contact Point (Complete items directly below for identification of individual to be contacted, if necessary, to process this application.)</b>		
<b>Name</b> Glenda Akins	<b>Title</b> Regulatory Affairs Mgr	<b>Telephone No. (Include Area Code)</b> 901-272-6268
<b>Certification</b> I certify that the statements I have made on this form and all attachments thereto are true, accurate and complete. I acknowledge that any knowingly false or misleading statement may be punishable by fine or imprisonment or both under applicable law.		<b>6. Date Application Received</b> (Stamped)
<b>2. Signature</b> 		<b>3. Title</b> Regulatory Affairs Manager
<b>4. Typed Name</b> Glenda Akins		<b>5. Date</b> Jan 23, 2013

4/10

January 25, 2013

USEPA  
J. Campbell-McFarlane (PM34)  
Antimicrobials Division  
One Potomac Yard  
2777 S. Crystal Drive (South Building)  
Arlington, VA 22202

RE: W-60-1 (Notification)  
EPA Reg. No.: 1448-114

Ms. McFarlane,

Please find enclosed a notification of unit packaging for the above referenced product. On the last one of these notifications for another registration I received a call from EPA requesting copies of the labels. Therefore, I am also enclosing copies of the product labels. There are four labels in order to accommodate the container rule storage and disposal requirements for different container sizes and types.


If you need any additional information please do not hesitate to contact me.

Sincerely,

BUCKMAN LABORATORIES, INC.



Glenda Atkins  
Regulatory Affairs Manager  
Attachments



ATTACHMENT FOR


Buckman Laboratories

EPA Registration No. 1448-114

Product Name: W-60-1

Section III (Continued)

Container Sizes: Unit Packaging (12- 1 quart containers per unit)







8/10

Buckman Laboratories  
Product Name: W-60-1

EPA Reg. No. 1448-114

"This notification is consistent with the provisions of PR Notice 98-10 and EPA regulations at 40 CFR 152.46, and no other changes have been made to the labeling or confidential statement of formula of this product. I understand that it is a violation of the 18 U.S.C. Sec. 1001 to willfully make any false statement to EPA. I further understand that if this notification is not consistent with the terms of PR Notice 98-10 and 40 CFR 152.46, this product may be in violation of FIFRA and I may be subject to enforcement action and penalties under sections 12 and 14 of FIFRA."

cccccc  
c l e  
e c e  
c  
cccccc  
c c c  
c c c  
c c  
cccccc  
c c  
cccccc  
c e  
cccccc  
e e  
cccccc  
c  
c c e  
c c l  
c c l l

# Buckman

# W-60-1

### ACTIVE INGREDIENT(S)

Poly(oxyethylene(dimethylamino)ethylene dichloride).....

60.0%

40.0%

100.0%

### INERT INGREDIENTS.....

TOTAL.....

## KEEP OUT OF REACH OF CHILDREN

## CAUTION

### FIRST AID

- If in Eyes: - Hold eye open and rinse slowly and gently with water for 15-20 minutes. Remove contact lenses, if present, after the first 5 minutes, then continue rinsing eye. - Call a poison control center or doctor for further treatment advice.
- If on Skin: - Take off contaminated clothing. - Rinse skin immediately with plenty of water for 15-20 minutes. - Call a poison control center or doctor for treatment advice.
- If Swallowed: - Have person sip a glass of water, if able to swallow. - Do not induce vomiting unless told to do so by the poison control center or doctor. - Move person to fresh air. - If person is not breathing, call 911 or an ambulance, then give artificial respiration, preferably by mouth-to-mouth if possible. - Call a poison control center or doctor for further treatment advice.

### HOT LINE NUMBER

Have the product container or label with you when calling a Poison Control Center or doctor or going for treatment. You may also contact 901-767-2722 for emergency medical treatment information.

## Precautionary Statements

### HAZARDS TO HUMANS AND DOMESTIC ANIMALS

**CAUTION:** Causes moderate eye irritation. Harmful if swallowed or absorbed through the skin. Avoid breathing vapors. Avoid contact with skin, eyes, or clothing. Wear chemical-resistant eyewear. Wash thoroughly with soap and water after handling and before eating, drinking, chewing gum, using tobacco, or using the toilet. Remove and wash clothing before reuse.

**ENVIRONMENTAL HAZARDS:** This pesticide is toxic to fish, aquatic organisms and clams. Do not discharge effluent containing this product into lakes, streams, ponds, estuaries, oceans or other waters unless in accordance with the requirements of a National Pollutant Discharge Elimination System (NPDES) permit and the permitting authority has been notified in writing prior to discharge. Do not discharge effluent containing this product to sewer systems without previously notifying the local sewage treatment plant authority. For guidance contact your State Water Board or Regional Office of the EPA.

### Directions for Use

It is a violation of Federal law to use this product in a manner inconsistent with its labeling. W-60-1 is used to control the growth of algae in swimming pools, heated swimming pools, exterior spas, whirlpools, hot tubs and decorative fountains that do not contain fish. It is also used to control algae, bacteria, fungi in recirculating commercial and industrial water cooling towers and recirculating cooling systems.

**WATER COOLING SYSTEMS:** Prior to the use of W-60-1 in water cooling towers, clean the systems to remove algal growth, microbiological slime, and other deposits. Then make an initial slug addition of 0.9 to 2.2 fluid ounces of W-60-1 per 1000 gallons of water to provide 8 to 20 ppm W-60-1, based on the total weight of water in the system. Repeat initial dosage until control is evident. Make subsequent slug additions of 0.2 to 2.2 fluid ounces of W-60-1 per 1000 gallons of water (2 to 20 ppm W-60-1) every 2 to 5 days or as needed. The frequency of addition depends upon the relative amount of bleedoff and the severity of the microbiological problem. Make slug additions in the sump of water cooling towers.

**INDUSTRIAL AIR WASHING SYSTEMS:** W-60-1 is used to control bacteria in industrial air washing systems that maintain effective mist eliminating components. Prior to its use, clean the systems to remove bacterial slime and other deposits. Use an initial slug dose of 3.33 to 5.55 fluid ounces of W-60-1 per 1000 gallons of water. Repeat initial dosage until control is evident. Make subsequent slug additions of 2.25 to 5.55 fluid ounces of W-60-1 per 1000 gallons of water each 1 to 5 days, or as needed. The frequency of addition depends upon the relative amount of bleedoff and severity of the bacterial problem. Make slug additions into the sump or into the water collection trays of the airwash system.

**SWIMMING POOLS, EXTERIOR SPAS, WHIRLPOOLS AND HOT TUBS:** For maximum effectiveness of W-60-1 in swimming pools, heated swimming pools, exterior spas, whirlpools and hot tubs, clean those systems with heavy growth of algae prior to using W-60-1.

For pools having just visible algae growth, add an initial dose of 11 to 17 fluid ounces of W-60-1 per 10,000 gallons of water and remove settled algae debris by cleaning. For treatment of a freshly cleaned and filled pool, add initially 6 to 11 fluid ounces of W-60-1 per 10,000 gallons of water. To maintain pools free of visible algae growth, make subsequent additions of 2 to 4 fluid ounces of W-60-1 per 10,000 gallons of water every 5 to 7 days after the initial treatment. Uniform distribution of W-60-1 throughout the water in the pool is necessary for maximum effectiveness.

Spas, whirlpools and hot tubs having just visible algae growth require an initial dose of 1 to 2 fluid ounces of W-60-1 per 1000 gallons of water. For treatment of a freshly cleaned spa, whirlpool or hot tub, add 0.6 to 1.1 fluid ounces of W-60-1 per 1,000 gallons of water. Make subsequent additions of 0.2 to 0.4 fluid ounces of W-60-1 every 5 to 7 days after initial treatment for maintenance.

W-60-1 will prevent growth of most algae during the off-season winter months when pools are not in use. For pools, which have been properly treated during the swimming season and are free of visible algae, add 6 to 10 fluid ounces of algicide per 10,000 gallons of water. If, at the end of the swimming season, pools have some visible algae growth, add 12 to 17 fluid ounces per 10,000 gallons. It is necessary that a uniform distribution of algicide throughout the water and the pool be made for maximum effectiveness. If pool is not covered, it may be necessary to repeat the treatment one or more times during the season.

W-60-1 is compatible with these chemicals normally used to treat pools and is effective at both acid and alkaline pH. W-60-1 can be used in pools treated with chlorine chemicals and may reduce the amount of those chemicals normally required. However, do not mix W-60-1 with concentrated dry or liquid chlorine products.

**DECORATIVE FOUNTAINS:** W-60-1 is used to control the growth of algae in decorative fountains that do not contain fish. Manually clean heavy growths of algae prior to treatment. Fountains with just visible algae growth require an initial dose of 1.0 to 2.0 fluid ounces of W-60-1 per 1000 gallons of water. To treat a freshly cleaned and filled fountain, add 0.5 to 1.5 fluid ounces of W-60-1 per 1000 gallons of water. For maintenance dosages, add 0.2 to 0.5 fluid ounces of W-60-1 per 1000 gallons of water every 5 to 7 days as needed. Make sure W-60-1 is added at a point where it can be uniformly distributed. W-60-1 may be used in fountains treated with chlorine chemicals, but do not mix W-60-1 with concentrated dry or liquid chlorine products.

### Storage and Disposal

Do not contaminate water, food, or feed by storage or disposal. Do not ship with Food, Feed, Drugs, or Clothing.

**PESTICIDE STORAGE:** Do not stack more than four drums high. Leaking or damaged drums should be placed in overpack drums for disposal. In case of spills, use sawdust or sand to absorb the spilled pesticide and disposed of in a sanitary landfill. Keep container closed when not in use.

**HAZARDOUS DISPOSAL:** Pesticide wastes may be hazardous. Improper disposal of excess pesticide, spray mixture, or rinsate is a violation of Federal Law. If these wastes cannot be disposed of by use according to label instructions, contact your State Pesticide or Environmental Control Agency, or the Hazardous Waste representative at the nearest EPA Regional Office for guidance.

**CONTAINER HANDLING:** Refillable container. Refill this container with pesticide only. Do not reuse this container for any other purpose. Cleaning the container before final disposal is the responsibility of the person disposing of the container. Cleaning before refilling is the responsibility of the refiller.

To clean the container prior to refilling or disposal, use a pressure wash as follows: Empty the remaining contents into application equipment or a mix tank. Use a pressure wash system that rinses all interior sides with water, and that is rated at >40 psi and >120F. Pressure wash the container for a length of time that ensures that a minimum 25% of the container volume of water is used. During the pressure wash, ensure that the container valve is left open for continuous draining. Collect the rinsate and empty into application equipment or a mix tank or store rinsate for later use or disposal. Allow container to drain for 10 minutes after pressure wash is completed.

### \*\*\* Specimen Label \*\*\*

Manufactured by  
**Buckman Laboratories, Inc.**  
1258 North McLean Blvd.  
Memphis, Tennessee 38108, USA  
(901) 278-0330 or 1-800-282-5626

EPA Est. No. 1448-TN-1

EPA Reg. No. 1448-114

Product Weight 9.6 lbs./gal. 1.15 kg/L

Net contents are marked on the container.

### HMIS / NPCA Ratings

Health 1 Flammability 1 Reactivity 0

Last Revision 7/25/2011

Refillable Greater Than 55 Gallons

9/10

# Buckman

# W-60-1

### ACTIVE INGREDIENT(S)

Poly(oxyethylene)(dimethyliminio)ethylene dichloride

INERT INGREDIENTS..... 60.0%

TOTAL..... 100.0%

**KEEP OUT OF REACH OF CHILDREN  
CAUTION**

FIRST AID	
If in Eyes	- Hold eye open and rinse slowly and gently with water for 15-20 minutes. - Remove contact lenses, if present, after the first 5 minutes, then continue rinsing eye. - Call a poison control center or doctor for further treatment advice.
If on skin, clothes	- Take off contaminated clothing. - Rinse skin immediately with plenty of water for 15-20 minutes. - Call a poison control center or doctor for treatment advice.
If Swallowed	- Call poison control center or doctor immediately for treatment advice. - Have person sip a glass of water, if able to swallow. - Do not induce vomiting unless told to do so by the poison control center or doctor. - Do not give anything by mouth to an unconscious person.
If inhaled	- Move person to fresh air. - If person is not breathing, call 911 or an ambulance, then give artificial respiration, preferably by mouth-to-mouth if possible. - Call a poison control center or doctor for further treatment advice.
HOT LINE NUMBER	
Have the product container or label with you when calling a Poison Control Center or doctor or going for treatment. You may also contact 901-767-2722 for emergency medical treatment information.	

### Precautionary Statements

#### HAZARDS TO HUMANS AND DOMESTIC ANIMALS

**CAUTION:** Causes moderate eye irritation. Harmful if swallowed or absorbed through the skin. Avoid breathing vapors. Avoid contact with skin, eyes, or clothing. Wear chemical-resistant gloves. Wash thoroughly with soap and water after handling and before eating, drinking, chewing gum, using tobacco, or using the toilet. Remove and wash clothing before reuse.

**ENVIRONMENTAL HAZARDS:** This pesticide is toxic to fish, aquatic organisms and clams. Do not discharge effluent containing this product into lakes, streams, ponds, estuaries, oceans or other waters unless in accordance with the requirements of a National Pollutant Discharge Elimination System (NPDES) permit and the permitting authority has been notified in writing prior to discharge. Do not discharge effluent containing this product to sewer systems without previously notifying the local sewage treatment plant authority. For guidance contact your State Water Board or Regional Office of the EPA.

### Directions for Use

It is a violation of Federal law to use this product in a manner inconsistent with its labeling. W-60-1 is used to control the growth of algae in swimming pools, heated swimming pools, exterior spas, whirlpools, hot tubs and decorative fountains that do not contain fish. It is also used to control algae, bacteria, fungi in recirculating commercial and industrial water cooling towers and recirculating cooling systems.

**WATER COOLING SYSTEMS:** Prior to the use of W-60-1 in water cooling towers, clean the systems to remove algal growth microbiological slime, and other deposits. Then make an initial slug addition of 0.9 to 2.2 fluid ounces of W-60-1 per 1000 gallons of water to provide 8 to 20 ppm W-60-1, based on the total weight of water in the system. Repeat initial dosage until control is evident. Make subsequent slug additions of 0.2 to 2.2 fluid ounces of W-60-1 per 1000 gallons of water (2 to 20 ppm W-60-1) every 2 to 5 days or as needed. The frequency of addition depends upon the relative amount of bleedoff and the severity of the microbiological problem. Make slug additions in the sump of water cooling towers.

**INDUSTRIAL AIR WASHING SYSTEMS:** W-60-1 is used to control bacteria in industrial air washing systems that maintain effective mist eliminating components. Prior to its use, clean the systems to remove bacterial slime and other deposits. Use an initial slug dose of 3.33 to 5.55 fluid ounces of W-60-1 per 1000 gallons of water. Repeat initial dosage until control is evident. Make subsequent slug additions of 2.25 to 5.55 fluid ounces of W-60-1 per 1000 gallons of water each 1 to 5 days, or as needed. The frequency of addition depends upon the relative amount of bleedoff and severity of the bacterial problem. Make slug additions into the sump or into the water collection trays of the airwash system.

**SWIMMING POOLS, EXTERIOR SPAS, WHIRLPOOLS AND HOT TUBS:** For maximum effectiveness of W-60-1 in swimming pools, heated swimming pools, exterior spas, whirlpools and hot tubs, clean those systems with heavy growth of algae prior to using W-60-1.

For pools having just visible algae growth, add an initial dose of 11 to 17 fluid ounces of W-60-1 per 10,000 gallons of water and remove settled algae debris by cleaning. For treatment of a freshly cleaned and filled pool, add initially 6 to 11 fluid ounces of W-60-1 per 10,000 gallons of water. To maintain pools free of visible algae growth, make subsequent additions of 2 to 4 fluid ounces of W-60-1 per 10,000 gallons of water every 5 to 7 days after the initial treatment. Uniform distribution of W-60-1 throughout the water in the pool is necessary for maximum effectiveness.

Spas, whirlpools and hot tubs having just visible algae growth require an initial dose of 1 to 2 fluid ounces of W-60-1 per 1000 gallons of water. For treatment of a freshly cleaned spa, whirlpool or hot tub, add 0.8 to 1.1 fluid ounces of W-60-1 per 1,000 gallons of water. Make subsequent additions of 0.2 to 0.4 fluid ounces of W-60-1 every 5 to 7 days after initial treatment for maintenance.

W-60-1 will prevent growth of most algae during the off-season winter months when pools are not in use. For pools, which have been properly treated during the swimming season and are free of visible algae, add 6 to 10 fluid ounces of algaecide per 10,000 gallons of water. If, at the end of the swimming season, pools have some visible algae growth, add 12 to 17 fluid ounces per 10,000 gallons. It is necessary that a uniform distribution of algaecide throughout the water and the pool be made for maximum effectiveness. If pool is not covered, it may be necessary to repeat the treatment one or more times during the season.

W-60-1 is compatible with those chemicals normally used to treat pools and is effective at both acid and alkaline pH. W-60-1 can be used in pools treated with chlorine chemicals and may reduce the amount of those chemicals normally required. However, do not mix W-60-1 with concentrated dry or liquid chlorine products.

**DECORATIVE FOUNTAINS:** W-60-1 is used to control the growth of algae in decorative fountains that do not contain fish. Manually clean heavy growths of algae prior to treatment. Fountains with just visible algae growth require an initial dose of 1.0 to 2.0 fluid ounces of W-60-1 per 1000 gallons of water. To treat a freshly cleaned and filled fountain, add 0.5 to 1.5 fluid ounces of W-60-1 per 1000 gallons of water. For maintenance dosages, add 0.2 to 0.5 fluid ounces of W-60-1 per 1000 gallons of water every 5 to 7 days as needed. Make sure W-60-1 is added at a point where it can be uniformly distributed. W-60-1 may be used in fountains treated with chlorine chemicals, but do not mix W-60-1 with concentrated dry or liquid chlorine products.

### Storage and Disposal

Do not contaminate water, food, or feed by storage or disposal. Do not ship with Food, Feed, Drugs, or Clothing.

**PESTICIDE STORAGE:** Keep container closed when not in use. In case of spills, use sawdust or sand to absorb the spilled pesticide and disposed of in a sanitary landfill.

**PESTICIDE DISPOSAL:** Wastes resulting from the use of this product may be disposed of on-site or at an approved waste disposal facility.

**CONTAINER HANDLING:** Nonrefillable container. Do not reuse or refill this container. Triple rinse container (or equivalent) promptly after emptying. Triple rinse as follows: Empty the remaining contents into application equipment or a mix tank and drain for 10 seconds after the flow begins to drip. Fill the container 1/4 full with water and recap. Shake for 10 seconds. Pour rinsate into application equipment or a mix tank or store rinsate for the later use or disposal. Drain for 10 seconds after the flow begins to drip. Repeat this procedure two more times.

Then offer for recycling if available or reconditioning, if appropriate, or by other procedures if approved by state and local authorities.

### \*\*\* Specimen Label \*\*\*

Manufactured by **Buckman Laboratories, Inc.**

1256 North McLean Blvd.  
Memphis, Tennessee 38108, USA

(901) 278-0330 or 1-800-282-5626

EPA Est. No. 1448-TN-1

EPA Reg. No. 1448-114

Product Weight 9.6 lbs./gal. 1.15 kg/L

Net contents are marked on the container.

### HMIS / NPCA Ratings

Health 1 Flammability 1 Reactivity 0

Last Revision 12/6/2011

NonRefillable Less Than Or Equal To 5 Gallons

10/10